

Certificate of Inspection

Invoice Address

Customer Ref :- 25619

Contact :- GORDON DUFF

Service Address

DUMFRIES TABLE TENNIS CLUB
79 SHAKESPEARE STREET
DUMFRIES
DG1 2JE

DUMFRIES TABLE TENNIS CLUB
79 SHAKESPEARE STREET
DUMFRIES
DG1 2JE

Technician :- Kevin Hitchell	F.E.T.A. No.-N/a	I.F.E.D.A. No.-	BAFE No-	
Loc.ID	Location	Type	Service	Corrective Action Required As Listed Below

1	Entrance	9.0 Ltr.Water	Basic Service	
2	Entrance	2.0 Kg Carbon-Dioxide	Overhauled	
3	Kitchen	2.0 Kg Carbon-Dioxide	Overhauled	
4	Kitchen	Fire Blanket	Installed	
5	Top Hall	3.0 Ltr.Water	Basic Service	
6	Top Hall	2.0 Kg Carbon-Dioxide	Overhauled	
7	Main Hall	9.0 Ltr.Water	Basic Service	

Maintenance Documentation

- 11. As portable fire extinguishers are regarded as "life safety equipment", it is the duty of the responsible person to ensure that a planned maintenance programme is in place, to ensure that the extinguishers are in an efficient state, in efficient working order, in good repair and suitable for the fire hazard.
- 11.1b) Apart from non-conforming extinguishers as recorded, all portable extinguishers have been maintained in accordance with BS 5306-3.
- 11.1d) Permanent replacement extinguishers are required to replace those extinguishers reported as condemned, corrective action required and/or missing'
- 11.1f) Replacement or additional extinguishers reported should be provided as soon as possible.

For this certificate to be valid, this certificate must be signed by the responsible person.

COMPETENT PERSONS SIGNATURE

RESPONSIBLE PERSONS SIGNATURE



.....

Dalbeattie Fire Protection Limited
Service Completed:- 08/2023

For on Behalf of Owner/Client
Next Service Due:-08/2024