

Certificate of Inspection

Invoice Address
Customer Ref :- 25619
Contact :- Kenny
Service Address

 DUMFRIES TABLE TENNIS CLUB
 79 SHAKESPEARE STREET
 DUMFRIES
 DG1 2JE

 DUMFRIES TABLE TENNIS CLUB
 79 SHAKESPEARE STREET
 DUMFRIES
 DG1 2JE

Technician :- Scott Learmont		F.E.T.A. No.-	I.F.E.D.A. No.-	BAFE No-
Loc.ID	Location	Type	Service	Corrective Action Required As Listed Below

1	Entrance	9.0 Ltr.Water	Basic Service	
2	Entrance	2.0 Kg Carbon-Dioxide	Basic Service	
3	Kitchen	2.0 Kg Carbon-Dioxide	Basic Service	
4	Kitchen	Fire Blanket	Basic Service	
5	Top Hall	3.0 Ltr.Water	Basic Service	
6	Top Hall	2.0 Kg Carbon-Dioxide	Basic Service	
7	Main Hall	9.0 Ltr.Water	Basic Service	

Maintenance Documentation

11. As portable fire extinguishers are regarded as "life safety equipment", it is the duty of the responsible person to ensure that a planned maintenance programme is in place, to ensure that the extinguishers are in an efficient state, in efficient working order, in good repair and suitable for the fire hazard.
- 11.1b) Apart from non-conforming extinguishers as recorded, all portable extinguishers have been maintained in accordance with BS 5306-3.
- 11.1d) Permanent replacement extinguishers are required to replace those extinguishers reported as condemned, corrective action required and/or missing'
- 11.1f) Replacement or additional extinguishers reported should be provided as soon as possible.

For this certificate to be valid, this certificate must be signed by the responsible person.

COMPETENT PERSONS SIGNATURE


 Dalbeattie Fire Protection Limited
 Service Completed:- 08/2026

RESPONSIBLE PERSONS SIGNATURE

 For on Behalf of Owner/Client
 Next Service Due:-08/2027